



Titeflex Corporation  
1116 Vaughn Parkway  
Portland, TN. 37148  
Tel. 833-798-4661  
[www.pythonls.com](http://www.pythonls.com)

## **Technical Bulletin TBPL2022-02**

### **Maximum Temperature**

**November 1, 2022**

**Gastite's Python Line Set product is tested and listed by the ICC-ES PMG 1675 program with a maximum temperature of 203°F and a maximum pressure of 700psi. The product has been tested and meets ASTM F3506-21 Specification for Polyethylene of Raised Temperature/Aluminum/Polyethylene of Raised Temperature (PE-RT/AL/PE-RT) Composite Pressure Pipe based on Inner Diameter (ID) for use in Air Conditioning and Refrigeration Line.**

