



Titeflex Corporation
1116 Vaughn Parkway
Portland, TN. 37148
Tel. 833-798-4661
www.pythonls.com

Technical Bulletin TBPL2022-03

UL 1963 & UL 207

November 1, 2022

Gastite's Python Line Set product has been tested and meets ASTM F3506-21 Specification for Polyethylene of Raised Temperature/Aluminum/Polyethylene of Raised Temperature (PE-RT/AL/PE-RT) Composite Pressure Pipe based on Inner Diameter (ID) for use in Air Conditioning and Refrigeration Line. This ASTM standard tests the product for refrigerant exposure, per section 58 of UL 1963 and also tests to section 14 "Fatigue Test" of UL 207. The Python Line Set product is compliant to ICC-ES LC 1039-2015, PMG Listing Criteria for PE-RT/AL/PE-RT Pipe and Fittings for Refrigeration Applications.

